

CEYY.R21090 - Outlet Boxes and Fittings Certified for Fire Resistance

Outlet Boxes and Fittings Certified for Fire Resistance

[See General Information for Outlet Boxes and Fittings Certified for Fire Resistance](#)

NOCOM GROUP INC

R21090

UNIT 1, 151 TANSLEY DR
OTTAWA, ON K0A 1L0 CANADA

Type MOI-DP1-COMM4, MOI-SYS-NOC-COMM, MOI-PWR4-COMM4 poke-through devices. May have various suffixes to identify device length, receptacle and data jack colors. For use in 1, 1 -1/2 or 2 hr rated unprotected reinforced concrete floors or concrete floors with suspended ceiling. (Fire resistance designs with suspended ceilings should have provisions for accessibility in the ceiling area below the poke-thru fittings.)

The assembled poke-through devices will not reduce the ratings of the floor assembly when the thickness and type of concrete (required for a specific rating) are within the specified limits and the device is installed as specified:

1. **Concrete** — Minimum 4-1/2 in. thickness of concrete slab. Unit weight of concrete to be 110 +/- 3 pcf.
2. **Installation** — Mounted in 4 in. diameter core-drilled holed in concrete per instructions accompanying devices.
3. **Spacing** — Minimum of 2 ft OC and not more than one device per each 65 sq ft of floor area in each span.

For the MOI-DP1-COMM4, maximum number of cable conductors in compartment of poke-through fitting not to exceed the aggregate cross-sectional area of the copper conductors for a total of 0.0387 sq.in. For faceplate may have any combination not to exceed a maximum area of 4 communication jacks and 1 duplex electrical receptacle.

For the MOI-SYST-NOC-COMM4, maximum number of cable conductors in compartment of poke-through fitting not to exceed the aggregate cross-sectional area of the copper conductors for a total of 0.0461 sq.in. For faceplate may have any combination not to exceed a maximum area of a Nocom 9 wire receptacle and an equivalent 1-1/4 diameter hole

For the MOI-PWR4-COMM4, maximum number of cable conductors in compartment of poke-through fitting not to exceed the aggregate cross-sectional area of the copper conductors of three 7/16 in. diam BX with 14 AWG wiring. For faceplate may have any combination not to exceed a maximum area of 4 communication jacks and 1 quad electrical receptacle.

Last Updated on 2015-03-12

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"

cookies on this website to enhance your navigation and to analyze our traffic. We also share information about your use of our site with our social media, advertising and analytics partners. [Learn More](#)

[Cookie Settings](#)

✓ [Accept](#)